

# Modul Digital 1208-10

Universal digital module for 8 digital outputs. For the connection of alarm sirens, door openers, etc.

## Module dimensions:

Evon Smart Home module type b (refer to technical data sheet module types) width/height/depth: 45,0mm/85,0mm/70,0mm  
Screw base depth 38,5mm Horizontal pitch [U] = 2,6 HU

Supply	
Power supply	24 Vdc +/-10 %
Nominal consumption	2W
Overvoltage category	2
Duty cycle	100%
Environmental conditions	
Operating conditions	-15..+55°C, 5..90 % rH, non-condensing
Storage conditions	-25..+70°C, 5..90 % rH, non-condensing
Pollution degree	2
Terminals	
Terminal capacity	max. 2 x 1,5 mm <sup>2</sup>
Screws	Pozidrive 1 / Slot 4 x 0,8 mm
Tightening torque	0,4 Nm
Protection type (EN 60529)	IP 20
Tests/Certification	
Recommended circuit breaker	B6 (IEC/EN 60898-1)
Output	
Type	Digital output
Sort	Potential-free relay contact, closer
Count	4
Terminals	Do 1..8
Max. resistive loads	1150W
Max. motor loads (cosPhi >= 0,95)	500W
Min. switching load	5V/1mA
Switching voltage AC	250V, 50/60Hz
Switching current AC (cosPhi = 1)	5A (250V)
Switching voltage DC	9..30V
Switching current DC	5A (24V)

## ATTENTION ELECTRICAL VOLTAGE


Disconnect all system components from the mains before commencing work.  
The components may ONLY cabled with the mains disconnected.  
The cabling may only be carried out by trained expert personnel.



## Important before commissioning:

- Supply every module with power.
- Please check whether the GND supply corresponds to the earth zero potential.
- Larger loads on the module outputs, together with capacitive and inductive loads, must be switched via relays.
- The input channel may only be switched with 24 V DC.

## Wiring example:



## Commissioning:

- Isolate the system from the mains before beginning commissioning.
- Start the installation work with a controller (e.g. iX800) or a converter module S1200 on the left-hand side of the cabinet.
- The modules can only be mounted from left to right.
- Plug the included 5-pole smartCOM line connector into the left terminal of the module.
- Mount the module on the DIN rail; it will click when seated correctly.
- Push the module along the rail to the left-hand module in the system. Ensure that the free pins of the connector snap into place in the socket of the adjacent module.
- Please check whether the GND supply for the 24 V power supply corresponds to an earth zero potential!
- Once the power is switched on, the ON LED lights up green.
- The smartCOM LED flashes red.
- Once the controller has recognized and addressed the modules, the smartCOM red LED is extinguished and the allocation and configuration can begin via visualization.

## Notes:

- Larger loads on the module outputs, together with capacitive and inductive loads, must be switched via relays
- C14/C58 can be used to integrate outputs with other separated potential levels.

## Modulabmessungen:

Evon Smart Home Modultype B (siehe Technisches Blatt Modultypen) Breite/Höhe/Tiefe: 45,0mm/85,0mm/70,0mm Schraubsockeltiefe 38,5mm Teilungseinheiten [TE] = 2,6 TE

Versorgung	
Versorgungsspannung	24 Vdc +/-10 %
Nennverbrauch	2W
Überspannungskategorie	2
Einschaltdauer	100%
Umgebungsbedingungen	
Betriebsbedingungen	-15..+55°C, 5..90 % rH, nicht kondensierend
Lagerbedingungen	-25..+70°C, 5..90 % rH, nicht kondensierend
Verschmutzungsgrad	2
Klemmen	
Klemmvermögen	max. 2 x 1,5 mm <sup>2</sup>
Schrauben	Pozidriv 1 / Slot 4 x 0,8 mm
Anzugsdrehmoment	0,4 Nm
Schutzart (EN 60529)	IP 20
Prüfungen/Zulassungen	
Empfohlene Sicherung	B6 (IEC/EN 60898-1)
Ausgang	
Typ	Digitalausgang
Art	pot. freier Relaiskontakt, Schließer
Anzahl	4
Klemmen	Do 1..8
Max. ohmsche Last	1150W
Max. Motorlast (cosPhi >= 0,95)	500W
Mindestlast	5V/1mA
Schaltspannung AC	250V, 50/60Hz
Schaltstrom AC (cosPhi = 1)	5A (250V)
Schaltspannung DC	9..30V
Schaltstrom DC	5A (24V)

## ACHTUNG ELEKTRISCHE SPANNUNG


Beim Arbeiten sämtliche Anlagenteile vom Stromnetz trennen. Die Verdrahtung der Komponenten darf NUR in spannungslosem Zustand durchgeführt werden. Die Verkabelung darf nur von geschultem und unterwiesenem Fachpersonal durchgeführt werden.



## Wichtig vor Inbetriebnahme:

- Jedes Modul mit Spannung versorgen.
- Bitte prüfen, ob die GND Versorgung Erd- Nullpotenzial entspricht.
- Größere ohmsche Lasten sowie kapazitive und induktive Lasten am Modulausgangskanal sind durch Relais zu schalten.
- Der Eingangskanal ist nur mit 24 V Gleichspannung zu schalten.

## Verdrahtungsbeispiel:



## Inbetriebnahme:

- Die Inbetriebnahme der Anlage spannungslos starten.
- Die Montagearbeiten mit einem Controller (z.B. iX800) oder einem Umsetzermodule S1200 an der linken Seite im Verteilerschrank beginnen.
- Die Module können immer nur von links nach rechts aufgebaut werden.
- Den beigelegten 5-poligen smartCOM-Line-Verbinder in die linke Steckerbuchse des Moduls stecken.
- Das Modul auf der DIN Hutschiene montieren, es schnappt mit einem Click ein.
- Das Modul auf der Hutschiene an das linke Modul im System schieben. Darauf achten, dass die freistehenden Pins der Steckverbindung in die Buchse des Nebenmoduls einrasten.
- Bitte prüfen, ob die GND Versorgung Ihres 24V Netzteils Erd- Nullpotenzial entspricht!
- Nach Spannungsversorgung leuchtet die ON LED in grün.
- Die smartCOM LED blinkt rot.
- Nachdem der Controller die Module erkannt und adressiert hat, erlischt die rote smartCOM LED und es kann mit der Zuordnung und Konfiguration über die Visualisierung begonnen werden.

## Anmerkungen:

- Größere ohmsche Lasten sowie kapazitive und induktive Lasten am Modulausgangskanal sind durch Relais zu schalten
- Über C14/C58 kann man auch Ausgänge anderer, getrennter Potenzialebenen einbinden.